

Reporting Municipality or Utility: Derby

Town where event occurred: Derby

Submitted by: Lindsay King

Phone number: 2037361475

Closest street address: Caroline Street

Weather conditions: Rain 3-4" per hour

Date and time event started: Tue Sep 25 19:05:00 EDT 2018

Date and time event ended: Tue Sep 25 19:00:00 EDT 2018

Location of bypass: Treatment Plant

Type of bypass: Raw Sewage

Cause of bypass: Excessive Flows - Storm Event

How was event discovered? slsrn

Estimated volume or quantity of bypass: 1,001 - 5,000 gallons

How was quantity determined? estimate

If reported, final volume or quantity: null

Did bypass reached a waterbody: No

Waterbody name: null

Comments: Excessive flows caused the Grit Chamber to overflow